



## NOTES:

1. AIR RELEASE RISER AND PVC PIPE HOUSING SHALL BE PLACED AND MAINTAINED IN VERTICAL POSITION.
2. METALLIC THREADS TO BE COATED WITH BITUMASTIC COATING.
3. INSTALL TAPPING SADDLE FOR THICKNESS CLASS D.I. MAINS 4" & SMALLER, PRESSURE CLASS D.I. MAINS 8" & SMALLER, OR WHEN MAIN IS PVC, HDPE, OR AC PIPE.
4. FOR MANHOLE/VALVE BOX IN GRASS AREAS, SEE SS 21.0 SHEET 1 OF 1.

TYPE "A" MANHOLE	SS 4.0	
ITEM	CROSS REF.	SPEC. REF.

ISSUE DATE	APPROVED BY
6/29/2011	F.A.